



Noise Level Study

Company	SMSA-HC Warehouse	Test Date : 22-05-2023
System No.	Storage Warehouse, Generator Area	
Type of Test	Noise Level Test	
Instrument Used	Sound Level Meter	
	Make - Testo , Model -Testo 815	

TEST RESULTS

Warehouse Name / Number	Recorded Value	Acceptance Limit (DB)	Pass/ Fail	Remarks
Warehouse No.-1	60.7	65	Pass	NIL
Warehouse No.-2	61.4	65	Pass	NIL
Warehouse No.-3	63.2	65	Pass	NIL
Warehouse No.-4	60.9	65	Pass	NIL
Warehouse No.-5	61.4	65	Pass	NIL
Warehouse No.-6	61.7	65	Pass	NIL
Warehouse No.-7	60.4	65	Pass	NIL
Warehouse No.-8	61.3	65	Pass	NIL
Warehouse No.-9	62.1	65	Pass	NIL
Warehouse No.-10	61.4	65	Pass	NIL
Generator Area	69.1	70	Pass	NIL

Done By:  22-05-2023